GRID RESILIENCE REPORT | DISCLAIMER

Disclaimer

This document: (a) is proprietary and confidential to Baringa Services Ltd ("Baringa") and could not be disclosed to or relied upon by any third parties or re-used without Baringa's consent; (b) shall not form part of any contract nor constitute acceptance or an offer capable of acceptance; (c) excludes all conditions and warranties whether express or implied by statute, law or otherwise; (d) places no responsibility or liability on Baringa or its group companies for any inaccuracy, incompleteness or error herein; and (e) is provided in a draft condition "as is" without warranty. Any reliance upon the content shall be at user's own risk and responsibility. If any of these terms is invalid or unenforceable, the continuation in full force and effect of the remainder will not be prejudiced.

Copyright © Baringa Services Limited 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information. No part of this document may be reproduced without the prior written permission of Baringa Services Limited.

This report has been prepared by Baringa Services Ltd or a Baringa group company ("Baringa") specifically for the client named in this report ("Client") for the sole purpose of assisting the consideration of Client or interested investors ("Investors") in the potential transaction named in this report ("Transaction").

This report does not constitute a personal recommendation of Baringa or take into account the particular investment objectives, financial situations, or needs of Client or the Investors in relation to the Transaction. Client and Investors could consider whether the content of this report is suitable for their particular circumstances and, if appropriate, seek their own professional advice and carry out any further necessary investigations before deciding whether or not to proceed with the Transaction. This report could not, under any circumstances, be treated as a document containing complete and accurate information sufficient to make an investment decision. It is the responsibility of the Client and Investors to conduct such due diligence as necessary of any risk factors not identified in this report or which could affect the operation, financial standing and further development prospects of any assets being acquired, charged or sold in the Transaction. Baringa shall not be liable in any way for errors or omissions in information contained in this report based upon publicly available industry data or specific information provided by others (including Client, its affiliates, their advisers, target entity or any third parties). Baringa makes no representations or warranties (express or implied) concerning the accuracy or completeness of the information contained in this report, nor whether such information fully reflects the actual situation described in this report, and all conditions and warranties whether express or implied by statute, law or otherwise are excluded.

Information and data contained in this report is confidential and must not be disclosed to third parties by Client or Investors except as permitted in the relevant Client contract with Baringa or with the written consent of Baringa. This report may not be used in any processes involving the public offering in which shares of stock in a company are sold either privately or on a securities exchange. No part of this Report may be copied, photocopied or duplicated in any form by any means or redistributed (in whole or in part) except as permitted in the relevant Client contract with Baringa or with the written consent of Baringa. Copyright © Baringa Services Ltd 2024. All rights reserved.







Grid Resilience Reports

Colorado

Energy & Resources | Networks 10/23/2024



Table of contents

Project Context	
 Project Context & Approach 	4-6
Deliverable Overview	
Climate Science Background	8
Data Sources	9-11
Analysis Approach	12
Grid Resilience Report	
Assets Class Overview	13-15
Wildfire	16-19
• Flood	20-22
• Wind	23-26
Heat	27-31
• Cold	32-35
• Drought	36-38
Precipitation	39-40



Grid Resilience Reports

Climate Science Background, Data Sources, and Analysis Approach

RCPs and SSPs provide viable climate pathways for an uncertain future

ipcc


Generating Emission Scenarios

- Representative concentration pathways (RCPs) project GHG concentrations: Defined by the IPCC in 2014 as scenarios of future emission concentrations and other radiative forcing that align to climate projections. 1 RCPs use assumptions relating to policy decisions and individual behavior that may change future GHG emissions concentrations. 1 SSPs have largely replaced RCPs.
- Shared socioeconomic pathways (SSPs) provide 5 'storylines' to contextualize RCPs and to provide the various future pathways possible.² They consider how the world could evolve socioeconomically and politically, including how various levels of climate change mitigation and adaptation could be achieved and will influence future climate scenarios.3
- RCPs included in the CLIMRR dataset include RCP 4.5 and RCP 8.5.
- SSPs included in the Hydrosource dataset include SSP585, SSP370, SSP245, and SSP126.

Modeling Scenario: RCP 4.5

- "Moderate" scenario: Emissions peak around 2040 and then slowly begin to decline.⁴ Temperatures warm about 3.2 °F from a 2000 baseline.⁵
- CO2 emissions plateau before falling mid-century, as energy use sharply declines and there is large scale reforestation. 6

Representative Concentration Pathway (RCP)



GRID-Arendal/Studio Atlantis, 2021

Modeling Scenario: RCP 8.5

- "Rapid growth" scenario: Emissions continue to rise throughout the twenty-first century.4 Temperatures warm about 6.6 °F from a 2000 baseline. 5
- CO2 emissions are three times higher than the present by end-century, with a large increase in methane emissions and continued fossil fuel use. 6



¹ Source: ComEd Vulnerability Study 2023 ⁴ Source: Help (cal-adapt.org)

² Source: Jupiter

³ Source: Carbon Brief

⁵ CoastAdapt


⁶ Climate Copernicus

Baringa leverages national downscaled climate datasets with high granularity to assign county-level climate exposure

	CLIMRR by Argonne National Lab (ANL)	HydroSource by Oak Ridge National Lab (ORNL)	RAWS by Western Regional Climate Center (WRCC)
Dataset Description	The Climate Risk and Resilience Portal (CLIMRR) provides highly localized climate projections from mid- to end-century using a supercomputer to model 60 climate variables.	HydroSource is a comprehensive national water energy digital platform consisting of hydropower-related data set, models, visualizations, and analytics tools.	The Wildland Fire Remote Automated Weather Stations (RAWS) data set provided by WRCC is a quality-controlled repository of hourly data for 17 select weather metrics from a network of weather stations across western states.
Data Provider Description	Argonne National Lab is a federally-funded science and engineering research center sponsored by the Department of Energy.	Oak Ridge National Lab is a federally funded research and development center sponsored by the Department of Energy.	The Western Regional Climate Center is one of 6 Regional Climate Centers in the United States. WRCC works jointly with NOAA to coordinate climate activities and conduct applied research on climate issues in the West.
Years Covered	Historical, Mid-Century, End-Century	1980-2099	2000-2022
Spatial Resolution	12 km (aggregated to county)	County	Weather station (aggregated to county)
Hazards	RAIN FIRE HEAT COLD DROUGHT	FLOOD	WIND



Baringa leverages national downscaled climate datasets with high granularity to assign county-level climate exposure (cont.)





Baringa is leveraging forward-looking climate projections to inform its technical assistance work for states in WECC



Wind

Source: Western Regional Climate Center (WRCC)

Input metric: Hourly max wind

speed (mph)

Output: Wind speed at key return

periods via GEV distribution



Wildfire

• Source: CLIMRR (ANL)

Input metric: Fire weather index

(FWI) by grid cell

Output: Maximum fire weather

index by county



Precipitation

Source: CLIMRR (ANL)

Input metric: Annual total precipitation (in/year) by grid cell

Output: Max annual total

precipitation (in/year) by county



Drought

Source: CLIMRR (ANL)

Input metric: Consecutive days with no precipitation by grid cell **Output:** Max consecutive days with no precipitation by county



Heat

Source: CLIMRR (ANL)

Input metrics:

- Days above 95, 105, 115, 125 °F
- Annual cooling degree days
- Seasonal maximum temperatures

Output: Input metrics applied from a grid cell level to a county level



Cold

Source: CLIMRR (ANL)

Input metrics:

- · Annual minimum temperature
- · Annual heating degree days
- Seasonal minimum temperatures

Output: Input metrics applied from a grid cell level to a county level



Flood

Source: Hydrosource (ORNL)

Input metric: Annual Variable Infiltration Capacity (VIC) model

runoff (mm/year)


Output: Average annual VIC runoff (pluvial flooding) for 4 warming scenarios and 3 time periods (historical, mid-century, end-century)




This report is standardized to include 3 different data visualizations that provide insights for Distribution, Transmission, and Generation across 7 extreme weather hazards




Distribution Maps



Transmission & Generation Maps



Statistical
Distribution Graphs



- Purpose: Uses population as proxy for volume of distribution assets given that the location of distribution assets is restricted.
- Interpretation*: Locate areas of high exposure by identifying counties with coincident large bubbles and dark colors. This indicates a combination of high volume of distribution (Dx) assets and significantly high extreme weather projections.
- **Purpose:** Overlays transmission and generation assets on climate projections by county.
- Interpretation: Locate areas of high exposure by identifying assets in counties of high risk. Exposure differs by asset class and will be highlighted in Key Insights tables throughout.
- Purpose: Contains statistical insights related to each metric. Indicates change in dispersion and severity of risk over time on average
- Interpretation: An increase in the width of the peak indicates a decrease in concentration of exposure, meaning more counties are exposed to more severe weather. A shift right in the curve indicates that on average, counties are experiencing more severe weather.



^{*}Note: Analysis addresses risk given volume of assets and does not account for risk to remote customers at end of radial distribution grids.

Asset Class Overviews

Summary









To better align with exposure, CO could consider expanded wildfire mitigation investment and evaluate whether existing hardening projects effectively address heat and cold

Key Takeaways

- Consider emergency response programs to act on new data and transmission and distribution hardening in W counties with high levels of fire exposure.
- Explore methods to offset generator derating and consider funding substation upgrade projects to mitigate the risk of direct asset failure.
- Consider new weatherization programs for thermoelectric assets and evaluate whether cold exposure is being adequately addressed by existing projects.

		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1				
Hazard	Exposure	Change to Mid- Century	Generation	Transmission & Distribution (Tx & Dx)	AWPI*	Description
FIRE	Н		 Consider investment in emergency response and thermoelectric fortification CO could invest in emergency response projects that act on the new data gleaned from drone inspection and monitoring. Consider initiatives to mitigate fire spread from contact with flammable fuel stockpiles. 	 Consider Tx and Dx hardening in western counties Western counties could be prioritized for Dx hardening projects, especially areas with high asset density such as Mesa County. High-voltage Tx lines running through western counties could be prioritized for hardening given high levels of fire exposure. 	М	Gen: No proposed awards address generator wildfire exposure, although most gen assets face low exposure. T&D: Undergrounding, vegetation management, and other wildfire mitigation projects demonstrate alignment with exposure, but CO could prioritize western counties.
HEAT	М		 Explore demand response (DR) or enhanced cooling methods to offset derating of supply DR programs exhibit synergies with ongoing microgrid investment and can combat thermoelectric production derates. Innovative thermoelectric cooling combats production derates and drought exposure. 	 Consider substation upgrades and more costeffective Tx hardening methods Significant exposure to days >105 °F requires substation upgrades to avoid direct failure. Widespread heat exposure necessitates upgrades that harden the entire length of a high-voltage (HV) transmission line, especially in the SE and SW. 	М	Gen: Microgrids for Community Resilience (MCR) program addresses derating of large generators. T&D: No mention of substation upgrades, which face considerable extreme heat exposure and a high likelihood of failure.
COLD	М	•	Continue to monitor the efficacy of generator winterization upgrades Many utilities have indoor gas units and winterized wind generation but could continue to monitor whether these upgrades are working effectively.	 Explore opportunities to address cold and fire exposure simultaneously in western counties Icing exposure is likely to remain low due to warming temperatures and a dry atmosphere. Consider vegetation management to address snow loading on trees near Dx assets. 	М	Gen: No proposed awards address generator cold exposure. T&D: Hardening projects may address cold exposure but appear heavily tailored towards wildfire.

^{*} AWPI = Alignment with proposed investment (40101(d) Round 1 project proposals)













CO could prioritize generator hardening investment addressing drought and consider substation fortification and distribution pole upgrades to combat flood exposure



- CO could evaluate whether undergrounding projects increase flood exposure and prioritize substation fortification and distribution pole upgrades.
- · Assets could be upgraded to withstand wind speeds up to 130 mph in the most exposed counties under a worst-case scenario.
- CO could seek out information about drought trends, precipitation timing, and snow patterns to better assess the impact on WAPA hydro generation.

Hazard	Exposure	Change to Mid- Century	Generation	Transmission & Distribution (Tx & Dx)	AWPI*	Description
≈ FLOOD	М	1	Generators are generally not significantly exposed to flood A solar project in Pitkin County is exposed, which could damage inverters or other ground-based equipment.	 CO could prioritize substation fortification Pockets of high-voltage substations are heavily exposed to flooding, especially in San Juan County, which can cause direct failure. CO could also consider upgrades to aging or weak distribution poles. 	L	Gen: Lack of exposure makes this a lower priority for investment. T&D: No projects targeting substations, unaligned with the significant substation exposure.
WIND	М	>	Consider hardening for renewable generators in highly exposed regions Wind and solar assets in eastern counties are exposed to return values above their wind speed ratings, leading to asset damage.	CO could consider Tx structure and Dx pole upgrades along a high-exposure corridor CO could prioritize Tx and Dx hardening along a high-exposure corridor running through the central region of the state.	М	Gen: No projects addressing generator exposure. T&D: Undergrounding addresses wind, but CO could also consider pole upgrades.
₩ DROUGH	М	>	CO could monitor the impact of drought on WAPA hydro generation • ~5% of CO electricity comes from WAPA. • Water scarcity's impact on cooling is less significant given the retirement of many thermoelectric assets by 2030.	Drought exposure does not have a material impact on transmission and distribution assets	М	Gen: Suggested projects for heat and fire exposure also address drought, including solar O&M advances. Currently none of these types of projects have been funded.
RAIN	М	>	CO could consider other factors that impact hydroelectric output in the state Consider the possibility of more frequent extreme rainfall and changing snow patterns, not captured in annual metrics.	Precipitation exposure does not have a material impact on transmission and distribution assets	М	Gen: CO could gather additional information to assess the true impact of precipitation on hydro and pumped storage assets and its implications for resource planning and scheduling.

^{*} AWPI = Alignment with proposed investment (40101(d) Round 1 project proposals)

^{12 |} Copyright @ Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information


Wildfire

Asset Analysis

Proposed 40101(d) projects in Colorado largely address wildfire exposure, but CO could prioritize projects in western counties and the buffer region between population centers

Colorado Summer Fire Weather Index (FWI)

Distribution Assets (Population), Historical




KEY OBSERVATIONS

- Wildfire exposure is concentrated in Colorado's western counties, corroborating findings from CO's EnviroScreen tool.
- Large population centers face about average wildfire exposure, but this
 could be underrepresented given proximity to highly exposed counties.
- Drone inspection, vegetation management, reconductoring, and undergrounding proposals indicate alignment with wildfire exposure.

Colorado Summer Fire Weather Index (FWI)

Distribution Assets (Population), End-Century [RCP-8.5]



KEY OBSERVATIONS

 FWI increases by about 3-6 points across the state, demonstrating the importance of utilizing forward-looking climate projections for statewide fire mitigation planning.



Mesa County faces peak state wildfire exposure, which given the county's relatively high population exposes a high density of distribution assets.




^{14 |} Copyright @ Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information



CO could prioritize transmission (Tx) hardening, asset access projects, and thermoelectric fortifications in western counties to address escalating wildfire exposure

Colorado Summer Fire Weather Index (FWI)

Generators & Transmission, Mid-Century [RCP-8.5]




Key Highlights	Analysis
£.770.3	 A high density of Tx assets are located in counties with high levels of wildfire exposure.
Transmission	 A key 345kV line cutting through southwestern counties faces peak state wildfire exposure, demonstrating a potential priority for future hardening investment.
	Wildfire causes ingress/egress issues through destruction of roads and transportation, slowing restoration times for all assets.
Restoration	 Drone inspection projects funded by CEO could cut restoration times by more effectively identifying issues, but CO could consider other projects that address access issues posed by wildfire.
	Coal and natural gas assets in Moffat and Mesa Counties face high wildfire exposure.
Thermoelectric	Flammable fuel stockpiles can accelerate fire spread if not fortified.

15 | Copyright @ Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information

Wildfire exposure exhibits minimal change by mid-century, but increases drastically in severity by end-century across a majority of the state

Colorado Average Seasonal Fire Weather Index (FWI)

Population-Weighted by County [RCP-8.5]




KEY OBSERVATIONS

- End-century wildfire exposure is elevated, with the sharpest increase occurring between spring and autumn by about 22% from historical FWI.
- Elevated wildfire exposure around the summer suggests a **lengthening of the wildfire season** combined with an **increase in severity.**
- The increase in the summer peak indicates that wildfire season will reach peak severity in the summer by end-century, compared to what is currently an autumn peak.

Colorado Fire Weather Index Statistical Distribution (FWI)

Population-Weighted by County [RCP-8.5]



KEY OBSERVATIONS

- Rightward shift of the curve by end-century demonstrates an increase in wildfire severity of about 5 FWI points across much of the state.
- The bi-modal shape of the curve represents two distinct hazard regions within the state, one large zone facing FWI between 15-20, and a smaller pocket facing extreme FWI exposure exceeding 22 points.
- Increase in P1 represents a wider spatial extent exposed to a FWI level of about 15 points by mid-century.




Flood

Asset Analysis

Flood exposure across the state is generally low, but CO could consider distribution fortification projects in mountain valley communities that face increasing exposure over time


Colorado Average Annual Surface Runoff (mm/year)
Historical [SSP5-8.5]



KEY OBSERVATIONS

- Most flood exposure lies in the **central-west counties** given their mountainous terrain and significant snowmelt.
- Generally **low levels of flood exposure in central population centers** given their higher elevations and flat terrain.
- Currently no proposed projects explicitly address flood exposure.

Colorado Average Annual Surface Runoff (mm/year)
End-Century [SSP5-8.5]



KEY OBSERVATIONS

- CO could consider prioritizing projects to fortify low-lying Dx substations given the increase in flood exposure over time in western counties.
- Summit and
- Pitkin Counties


Flood exposure is projected to increase about 20% by end-century, posing a substantial threat to low-lying substations and distribution poles.



While generators generally face low levels of flood exposure, CO could prioritize low-lying substation upgrades in a handful of high exposure counties

Colorado Average Annual Surface Runoff (mm/year)

Population-Weighted by County [SSP5-8.5]



Key Highlights	Analysis
5 Substation	 High-voltage (HV) substations will be exposed to pluvial flooding. Fluvial flooding is a risk if located in flood plain or riverbank without necessary protections. A pocket of HV substations in San Juan County are heavily exposed to flood risk, marking a priority for future hardening projects.
Restoration	 Flooding causes ingress/egress complications by washing out access roads, contributing to restoration issues. Flooding can affect on-site buildings or facilities, making it more difficult to maintain adequate staffing for oversight and restoration.
E Generators	 Generators are largely not exposed to flood risk, indicating that CO could prioritize transmission and distribution projects to address the hazard. A solar project in Pitkin County is highly exposed to flood, which could damage inverters and other ground-level equipment.



^{19 |} Copyright @ Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information.


Wind


Asset Analysis

CO could consider pole upgrades along mountain ranges in the central region of the state to complement existing undergrounding and vegetation management projects


Colorado 100-year Wind Speed (mph)

Historical












Medium-voltage (MV) transmission lines in the west and south-central portions of the state could be prioritized for hardening given their critical ties from large generators to load sinks

Colorado 100-year Wind Speed (mph)


Historical



Key Highlights	Analysis
	A series of MV transmission lines in the south-central and western portions of the state are exposed to high wind speeds. MV lines in Frament County are also
	 MV lines in Fremont County are also exposed to peak state wind exposure.
Transmission	These lines are crucial for connecting large thermoelectric generators to demand pockets. CO could focus on reinforcing transmission structures to mitigate risk.
	 A handful of solar farms throughout the state are exposed to 100-year return period values of > 100mph.
Renewables	 Depending on the supplier, solar panels are only rated to 90 mph, indicating need for rack reinforcement and vegetation management.
Wind	 Wind farm cutout speeds can vary between 45-70mph, indicating that in high wind speed events, the turbines stop producing. The cluster of large wind farms located in the eastern portion of the state are exposed to 100-year return period values far greater than the cutout threshold, impacting critical supply near population centers.



Historically, there is a 1% chance that the average wind speed seen across Colorado counties is ~80mph annually.






Heat

Asset Analysis

CO could consider distribution system upgrades addressing extreme heat to mitigate asset degradation, derating, and potential failure given escalating exposure over time

Colorado Days Above 105 °F

Distribution Assets (Population), Historical



KEY OBSERVATIONS


- Currently, transmission (Tx) and distribution (Dx) assets have no exposure to days above 105 °F.
- 105 °F is a particularly important threshold for distribution assets and substations, which can fail when exposed to two consecutive days above 104 °F.²

Source: ClimRR, US Census Bureau, City and Town Population Totals

25 | Copyright @ Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information

Colorado Days Above 105 °F

Distribution Assets (Population), End-Century [RCP-8.5]



KEY OBSERVATIONS

 Southeastern counties are expected to face about 16-20 days >105 °F annually, causing high asset utilization, derating, and potential failure.



Adams County will face over 3 days >105 °F by end-century, exposing a high density of Dx substations and transformers to derating, accelerated degradation, and potential failure.




¹Population bubbles are continuous and therefore labels are approximate. ²EPRI Climate READi

CO could consider additional investments to combat thermoelectric production and transmission capacity derates due to extreme heat given escalating exposure over time

Colorado Summer Average Maximum Temperature (°F)

Generators, Mid-Century [RCP-8.5]




Key Highlights	Analysis	
	 Natural gas and coal assets in the central portion of the state are heavily exposed to extreme heat. 	
Thermoelectric	 Thermoelectric generators that rely on water-based cooling methods will experience production derates as extreme heat raises average water temperatures. 	
	 CEO's proposed microgrid projects generally address derating during load shed events. 	
~	 A significant portion of transmission lines are exposed to high levels of extreme heat in the SW and SE, which can cause capacity derates and line sag. 	
Transmission	 Undergrounding proposals address these issues, but CO could consider more cost- effective adaptations like reconductoring to fortify transmission lines over longer distances. 	
Renewables	Extreme heat can cause solar production derates and shorten battery energy storage system (BESS) lifespans.	



^{26 |} Copyright © Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information

Days above 95 °F are projected to increase drastically over time, making derating and capacity violations key issues for CO to prioritize


Colorado Average Annual Cooling & Heating Degree Days (CDD & HDD) Population-Weighted by County [RCP-8.5]



KEY OBSERVATIONS

- Between historical and mid-century, the ratio of CDD to HDD
 increases, with the share of average number of CDD jumping from about
 12% to 18%.
- This increase in CDD results in increased summer asset utilization and degradation, but impacts to winter utilization remain unclear depending on heating electrification trends.
- CO could be mindful of the **impact of heating electrification on peak load** given significantly higher HHD levels than CDD levels.

Colorado Average Annual Days Exceeding Daily Max Heat Index Thresholds Population-Weighted by County [RCP-8.5]



KEY OBSERVATIONS


- >5x increase in days with heat index >95 °F by mid-century demonstrates an increase in peak load and will likely contribute to derating and capacity violations for transmission and thermal generating units.
- 2 days >105 °F by mid-century poses a risk to distribution substations, which can fail after two consecutive days above 104 °F.
- Utilities could prioritize planning for temperatures between 95-105 °F, making derating a higher priority than asset failure.



Average summer temperature maximums are projected to increase by mid-century, increasing the duration and magnitude of high system utilization

Colorado Average Seasonal Maximum Temperature (°F)

Population-Weighted by County [RCP-8.5]



Key Highlights	Analysis
Summer Warming	 Heat risk increases most drastically in summer, with a 6 °F increase in the average seasonal max by mid-century, increasing system utilization and accelerating asset degradation. Average summer minimum temperatures are also projected to increase (slide 34), which shortens the overnight cooldown period for assets.
Shorter Shoulder Seasons	There is generally less pronounced warming in shoulder seasons, although increased autumn maximums could extend the duration of high system utilization and shorten maintenance windows.




Cold

Asset Analysis

Western counties continue to face high extreme cold exposure year-round, prompting consideration of distribution hardening to combat freezing and snow loading

Colorado Average Annual Minimum Temperature (°F)

Distribution Assets, (Population) Historical




KEY OBSERVATIONS

- Extreme cold exposure is generally concentrated in the western half of the state, including population centers in the north-central region.
- Undergrounding and reconductoring projects appear tailored to wildfire, indicating that CO may want to consider additional hardening in highly exposed counties to address cold exposure.

Colorado Average Annual Minimum Temperature (°F)

Distribution Assets, (Population), End-Century [RCP-8.5]



KEY OBSERVATIONS

• Climate projections cannot predict acute extreme events like polar vortices and winter storms, **underrepresenting cold exposure.**




Larimer County is exposed to average annual minimum temperatures of ~28°F, indicting potential freezing and snow loading for distribution assets.



CO could prioritize hardening projects addressing extreme cold for heavily exposed thermoelectric assets and high voltage transmission lines in western counties

Colorado Average Annual Minimum Temperature (°F)

Generators, Mid-Century [RCP-8.5]



Key Highlights	Analysis
	 Coal plants in Moffat and Routt counties are heavily exposed to extreme cold, which can cause a variety of plant shutdowns and freezing of coal stockpiles.
Coal	 CO could consider generator hardening projects addressing extreme cold given a high density of large, exposed thermoelectric assets.
	 Natural gas plants in the north-central region border counties with extreme cold exposure, which could cause ignition failure or other performance issues.
Natural Gas	 Asset owners could evaluate whether plants have significant heating infrastructure to prevent freezing events.
E Hydroelectric	 Frazil ice formation and maloperation of spill gate motors can result in plant faults or production derates.
	 The prevalence of below-freezing annual minimums in many counties contributes to Tx freezing risk and snow loading that can cause asset failure.
Transmission	 CO could consider structure reinforcement upgrades to combat snow loading.



^{31 |} Copyright @ Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information

Winter minimum temperatures remain far below 32 °F despite moderate warming over time, indicating adaptations addressing freezing as a priority area for future CO investment.

Colorado Average Seasonal Minimum Temperature (°F)

Population-Weighted by County [RCP-8.5]


50 45 40 Degrees F 35 30 Historical 25 Mid Century End-Century +4 °F Winter Spring Summer Autumn

KEY OBSERVATIONS

- Significant winter heating (+4 °F by mid-century) will decrease overall heating load, but the impact on electricity demand ultimately depends on the speed of heating electrification.
- Mid-century winter minimums remain well below 32 °F, indicating that freezing and icing exposure persists despite warming.
- Few proposed projects address freezing risk despite significant exposure, demonstrating a priority area for future CO investment.

Colorado Average Annual Minimum Temperature (°F)

Population-Weighted by County [RCP-4.5, RCP-8.5]



KEY OBSERVATIONS

- Annual minimums close to 32 °F indicate significant freezing exposure for most of the year, demonstrating the need for relevant hardening upgrades such as undergrounding, reconductoring, etc.
- Regarding extreme cold, global climate models do not resolve for extreme cold events like polar vortexes, so assets could still face similar levels of exposure to cold-related failures despite moderate projected warming.




Drought

Asset Analysis

While drought exposure generally decreases by mid-century, CO could monitor trends given state-wide variation and consider integrating water scarcity forecasts into production planning

Colorado Consecutive Days No Precipitation

Generators, Mid-Century [RCP5-8.5]



Key Highlights	Analysis
	 A string of hydroelectric plants along the Gunnison River are exposed to above average state-wide drought levels.
Hydroelectric	 Asset owners and grid operators could consider monitoring drought trends throughout the river basin, which can vary significantly throughout the state.
	 Lack of water availability can reduce coal cooling ability and disrupt flue gas desulfurization systems, resulting in power production curtailments and increased emissions.
Coal	 Many coal generators will retire before mid- century, making this a less urgent area for investment.
Renewables	 Drought conditions cause dust buildup on solar panels, hurting capacity factors. In areas that also have high wildfire exposure, such as Montezuma and Mesa counties, panel cleaning projects address two hazards simultaneously.






Drought exposure is projected to vary by region and depends on warming levels, indicating that asset owners, particularly of hydroelectric generators, could monitor its trajectory closely

Colorado Average Annual Consecutive Days with No Precipitation


Population-Weighted by County [RCP 4.5, RCP-8.5]



KEY OBSERVATIONS

- Drought exposure increases by ~10% by mid-century (under RCP 4.5), contributing to potential asset cooling failures and reduced hydroelectric generation.
- Significant gap between drought exposure under the RCP-4.5 warming scenario and RCP-8.5 scenario indicate that drought does not scale linearly with temperature and could be monitored closely by asset owners and grid operators.

Colorado Average Consecutive Days with No Precipitation Statistical Distribution



KEY OBSERVATIONS

- Leftward shift of mid-century graph generally indicates decreasing drought severity, although a larger spatial extent is exposed to about 25 consecutive days without precipitation.
- Plateau shape of end-century curve indicates a more even spread of drought exposure throughout the state.
- Differing shapes indicate that exposure will vary regionally, and thus could be monitored closely by asset owners.




Precipitation

Asset Analysis

Precipitation remains relatively constant to mid-century, but CO could consider other factors that impact hydro output and cooling water availability such as timing and snow patterns

Colorado Annual Max Precipitation (in)

Generators, Mid-Century [RCP5-8.5]



Key Highlights	Analysis
	 Timing of precipitation has an important impact of hydro output.
	 Extreme rainfall events may overflow reservoirs and put more pressure on dams, increasing risk of failure.
Timing	 Blue Mesa Dam is exposed to peak state precipitation exposure, meaning asset owners could consider hardening to address extreme rainfall.
	 Mount Elbert Pumped Storage Plant in Lake County is exposed to above average precipitation and drought levels, indicating a propensity for extreme rain.
Pumped Storage	 Extreme precipitation can cause reservoir overflow and asset damage, prompting consideration of asset hardening.
	 While precipitation levels remain relatively constant to mid-century, precipitation type and timing is likely to change due to warming and could be monitored.
Changes to Snow Patterns	 Grid operators could consider the impacts of less snow and earlier snow melt when conducting long-term planning.


Source: ClimRR, US Census Bureau, City and Town Population Totals

37 | Copyright @ Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information

Appendix

Fire Weather Index synthesizes weather and moisture content data into a normalized value representing the danger of fire spread once ignition has occurred.

Structure of the Canadian Forest Fire Weather Index System



KEY TAKEAWAYS

- FWI is a useful metric for evaluating weather-based conditions that heighten the danger of wildfire spread once ignition has occurred.
- Initial Spread Index: Measures the expected rate of fire spread, based on wind speed and moisture content of fine fuels/forest litter (Fine Fuel Moisture Code).
- Buildup Index: Measures the total amount of forest fuel available for consumption, based on the moisture content of intermediate organic layers, such as decomposing plant matter (Duff Moisture Code), and the moisture content of deep organic layers and soils, which corresponds to drought measures (Drought Code).
- Daily FWI values were calculated using readings from Argonne's downscaled 12km climate data and averaged annually or seasonally across RCP-4.5 and RCP-8.5.
- Percentiles (below) were calculated based on FWI values across all
 12km grid cells in the contiguous U.S.

FWI Class	Percentile range in historical period	FWI values in Class
Low	0–25 th percentile	0–9 FWI
Medium	25–50 th percentile	9–21 FWI
High	50–75 th percentile	21–34 FWI
Very High	75–90 th percentile	34–39 FWI
Extreme	90–98 th percentile	39–53 FWI
Very Extreme	Above 98th percentile	Above 53 FWI

