

Disclaimer

This document: (a) is proprietary and confidential to Baringa Services Ltd (“Baringa”) and could not be disclosed to or relied upon by any third parties or re-used without Baringa’s consent; (b) shall not form part of any contract nor constitute acceptance or an offer capable of acceptance; (c) excludes all conditions and warranties whether express or implied by statute, law or otherwise; (d) places no responsibility or liability on Baringa or its group companies for any inaccuracy, incompleteness or error herein; and (e) is provided in a draft condition “as is” without warranty. Any reliance upon the content shall be at user’s own risk and responsibility. If any of these terms is invalid or unenforceable, the continuation in full force and effect of the remainder will not be prejudiced.

Copyright © Baringa Services Limited 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information. No part of this document may be reproduced without the prior written permission of Baringa Services Limited.

This report has been prepared by Baringa Services Ltd or a Baringa group company (“Baringa”) specifically for the client named in this report (“Client”) for the sole purpose of assisting the consideration of Client or interested investors (“Investors”) in the potential transaction named in this report (“Transaction”).

This report does not constitute a personal recommendation of Baringa or take into account the particular investment objectives, financial situations, or needs of Client or the Investors in relation to the Transaction. Client and Investors could consider whether the content of this report is suitable for their particular circumstances and, if appropriate, seek their own professional advice and carry out any further necessary investigations before deciding whether or not to proceed with the Transaction. This report could not, under any circumstances, be treated as a document containing complete and accurate information sufficient to make an investment decision. It is the responsibility of the Client and Investors to conduct such due diligence as necessary of any risk factors not identified in this report or which could affect the operation, financial standing and further development prospects of any assets being acquired, charged or sold in the Transaction. Baringa shall not be liable in any way for errors or omissions in information contained in this report based upon publicly available industry data or specific information provided by others (including Client, its affiliates, their advisers, target entity or any third parties). Baringa makes no representations or warranties (express or implied) concerning the accuracy or completeness of the information contained in this report, nor whether such information fully reflects the actual situation described in this report, and all conditions and warranties whether express or implied by statute, law or otherwise are excluded.

Information and data contained in this report is confidential and must not be disclosed to third parties by Client or Investors except as permitted in the relevant Client contract with Baringa or with the written consent of Baringa. This report may not be used in any processes involving the public offering in which shares of stock in a company are sold either privately or on a securities exchange. No part of this Report may be copied, photocopied or duplicated in any form by any means or redistributed (in whole or in part) except as permitted in the relevant Client contract with Baringa or with the written consent of Baringa. Copyright © Baringa Services Ltd 2024. All rights reserved.



GDO
GRID DEPLOYMENT OFFICE

Grid Resilience Reports

Oregon

Energy & Resources | Networks
10/23/2024

Table of contents

Project Context

- | | |
|------------------------------|-----|
| • Project Context & Approach | 4-6 |
|------------------------------|-----|

Deliverable Overview

- | | |
|------------------------------|------|
| • Climate Science Background | 8 |
| • Data Sources | 9-11 |
| • Analysis Approach | 12 |

Grid Resilience Report

- | | |
|-------------------------|-------|
| • Assets Class Overview | 14-15 |
| • Wildfire | 16-19 |
| • Flood | 20-22 |
| • Wind | 23-26 |
| • Heat | 27-31 |
| • Cold | 32-35 |
| • Drought | 36-38 |
| • Precipitation | 39-40 |

Grid Resilience Reports

Climate Science Background, Data Sources, and Analysis Approach

RCPs and SSPs provide viable climate pathways for an uncertain future



Generating Emission Scenarios


- **Representative concentration pathways (RCPs) project GHG concentrations:** Defined by the IPCC in 2014 as scenarios of future emission concentrations and other radiative forcing that align to climate projections.¹ RCPs use assumptions relating to policy decisions and individual behavior that may change future GHG emissions concentrations.¹ SSPs have largely replaced RCPs.
- **Shared socioeconomic pathways (SSPs) provide 5 ‘storylines’ to contextualize RCPs** and to provide the various future pathways possible.² They consider how the world could evolve socioeconomically and politically, including how various levels of climate change mitigation and adaptation could be achieved and will influence future climate scenarios.³
- RCPs included in the CLIMRR dataset include RCP 4.5 and RCP 8.5.
- SSPs included in the Hydrosorce dataset include SSP585, SSP370, SSP245, and SSP126.

Modeling Scenario: RCP 4.5

- **“Moderate” scenario:** Emissions peak around 2040 and then slowly begin to decline.⁴ Temperatures warm about 3.2 °F from a 2000 baseline.⁵
- CO2 emissions plateau before falling mid-century, as energy use sharply declines and there is large scale reforestation.⁶

Representative Concentration Pathway (RCP)

Scientists use the RCPs to model climate change and build scenarios about the impacts



GRID-Arendal/Studio Atlantis, 2021

Modeling Scenario: RCP 8.5

- **“Rapid growth” scenario:** Emissions continue to rise throughout the twenty-first century.⁴ Temperatures warm about 6.6 °F from a 2000 baseline.⁵
- CO2 emissions are three times higher than the present by end-century, with a large increase in methane emissions and continued fossil fuel use.⁶

¹ Source: ComEd Vulnerability Study 2023

² Source: Jupiter

³ Source: Carbon Brief

⁴ Source: [Help \(cal-adapt.org\)](http://cal-adapt.org)

⁵ CoastAdapt

⁶ [Climate Copernicus](https://climate.copernicus.eu)

Baringa leverages national downscaled climate datasets with high granularity to assign county-level climate exposure

	CLIMRR by Argonne National Lab (ANL)	HydroSource by Oak Ridge National Lab (ORNL)	RAWS by Western Regional Climate Center (WRCC)
Dataset Description	The Climate Risk and Resilience Portal (CLIMRR) provides highly localized climate projections from mid- to end-century using a supercomputer to model 60 climate variables.	HydroSource is a comprehensive national water energy digital platform consisting of hydropower-related data set, models, visualizations, and analytics tools.	The Wildland Fire Remote Automated Weather Stations (RAWS) data set provided by WRCC is a quality-controlled repository of hourly data for 17 select weather metrics from a network of weather stations across western states.
Data Provider Description	Argonne National Lab is a federally-funded science and engineering research center sponsored by the Department of Energy.	Oak Ridge National Lab is a federally funded research and development center sponsored by the Department of Energy.	The Western Regional Climate Center is one of 6 Regional Climate Centers in the United States. WRCC works jointly with NOAA to coordinate climate activities and conduct applied research on climate issues in the West.
Years Covered	Historical, Mid-Century, End-Century	1980-2099	2000-2022
Spatial Resolution	12 km (aggregated to county)	County	Weather station (aggregated to county)
Hazards	RAIN FIRE HEAT COLD DROUGHT	FLOOD	WIND

Baringa leverages national downscaled climate datasets with high granularity to assign county-level climate exposure (cont.)

	CLIMRR by Argonne National Lab (ANL)			HydroSource by Oak Ridge National Lab (ORNL)	RAWS by Western Regional Climate Center (WRCC)
Key Metrics	Seasonal Fire Weather Index	Annual Precipitation	Cons. Days w/o Precipitation		
	Days Above X°F Heat Index	Annual Cooling Degree Days	Seasonal Max Temperature	Annual VIC Runoff (SSP585)	Hourly Max Wind Gust
	Annual Min Temperature	Annual Heating Degree Days	Seasonal Min Temperature		
Mapping/Analysis	Used a Python script that returned the most extreme value (high or low depending on hazard) from grid cells intersecting a particular county.			Averaged across the 7 different climate model values provided for the SSP585 warming scenario to return a single, composite runoff level for each county in each year. 2000 was used for historical, 2050 for mid-century, and 2090 for end-century.	Mapped weather stations to their respective counties. If a county had multiple weather stations, the station with the highest average hourly value was selected to represent the county. Counties with no stations were mapped to the closest station in a neighboring county. GEV analysis was conducted using the pyextremes EVA function to derive return periods.
Rationale	• Reputable data provider • Accessible, open-source data allows for our methodology to be reproduced/quality checked • Provides climate projections for hazards with a significant climate signal • More than sufficient spatial resolution to gauge climate exposure at a county level			• Reputable data provider • Climate projections forecast change in exposure over time • Same spatial resolution as outage data (county level) • Data set includes pluvial flooding (from flash floods and surface runoff) which is more likely to contribute to outages because it is faster-acting and can hit urban centers	• Reputable data provider • Wind does not have a strong climate signal, so projections were not required • Sufficient density of stations per state to assign to counties • Quality checked • Hourly resolution was sufficient for deriving return periods



Baringa is leveraging forward-looking climate projections to inform its technical assistance work for states in WECC



Wind

Source: **Western Regional Climate Center (WRCC)**

Input metric: Hourly max wind speed (mph)

Output: Wind speed at key return periods via GEV distribution



Wildfire

• Source: **CLIMRR (ANL)**

Input metric: Fire weather index (FWI) by grid cell

Output: Maximum fire weather index by county



Precipitation

Source: **CLIMRR (ANL)**

Input metric: Annual total precipitation (in/year) by grid cell

Output: Max annual total precipitation (in/year) by county




Drought

Source: **CLIMRR (ANL)**

Input metric: Consecutive days with no precipitation by grid cell

Output: Max consecutive days with no precipitation by county



Heat

Source: **CLIMRR (ANL)**

Input metrics:

- Days above 95, 105, 115, 125 °F
- Annual cooling degree days
- Seasonal maximum temperatures

Output: Input metrics applied from a grid cell level to a county level



Cold

Source: **CLIMRR (ANL)**

Input metrics:

- Annual minimum temperature
- Annual heating degree days
- Seasonal minimum temperatures

Output: Input metrics applied from a grid cell level to a county level



Flood

Source: **Hydrosource (ORNL)**


Input metric: Annual Variable Infiltration Capacity (VIC) model runoff (mm/year)

Output: Average annual VIC runoff (pluvial flooding) for 4 warming scenarios and 3 time periods (historical, mid-century, end-century)

This report is standardized to include 3 different data visualizations that provide insights for Distribution, Transmission, and Generation across 7 extreme weather hazards

1


Distribution Maps



- **Purpose:** Uses population as proxy for volume of distribution assets given that the location of distribution assets is restricted.
- **Interpretation*:** Locate areas of high exposure by identifying counties with coincident large bubbles and dark colors. This indicates a combination of high volume of Dx assets and significantly high extreme weather projections.

2


Transmission & Generation Maps



- **Purpose:** Overlays transmission and generation assets on climate projections by county.
- **Interpretation:** Locate areas of high exposure by identifying assets in counties of high risk. Exposure differs by asset class and will be highlighted in Key Insights tables throughout.

3

Statistical Distribution Graphs



- **Purpose:** Contains statistical insights related to each metric. Indicates change in dispersion and severity of risk over time on average
- **Interpretation:** An increase in the width of the peak indicates a decrease in concentration of exposure, meaning more counties are exposed to more severe weather. A shift right in the curve indicates that on average, counties are experiencing more severe weather.

***Note:** Analysis addresses risk given volume of assets and does not account for risk to remote customers at end of radial distribution grids.

Asset Class Overviews

Executive Summaries

ODOE could prioritize hardening of T&D infrastructure for heat and cold exposure, and consider new programs to address generator extreme weather exposure

Key Takeaways

- Focus T&D hardening on the wildland-urban interface and eastern HV lines to address wildfire proliferation.
- Consider new weatherization programs for thermoelectric and hydroelectric assets in the NE and prioritize T&D hardening in western population centers.
- Continue DER investment to combat derating from heat and consider funding substation upgrade projects to mitigate the risk of direct asset failure.

Hazard	Exposure	Change to Mid-Century	Generation	Transmission & Distribution	AWPI*	Description
 FIRE	H		Consider investment in innovative solar O&M processes and emergency response planning • Standardized PSPS and emergency response planning could decrease restoration times. • Innovative solar cleaning projects or optimized maintenance scheduling could help combat low solar capacity factors during fires.	Focus hardening efforts on border counties and eastern HV Tx assets • Major population centers border high-exposure counties, posing a threat to Dx and Tx assets in the case of wildfire spread and growing by 22% to 2100 [RCP-8.5]. • High voltage Tx lines in Wasco and Malheur counties could be prioritized for hardening given their high levels of fire exposure.	M	Gen: No proposed awards address generator wildfire exposure, marking a potential area for future investment. T&D: Prevalence of undergrounding awards addresses fire risk, but their expense limits widespread implementation. ODOE could consider pole upgrades, vegetation management, AI monitoring tools, etc.
 HEAT	M		Explore flexible DER options or innovative cooling methods to offset derating of supply • DER proliferation minimizes reliance on a pocket of natural gas plants that will be heavily exposed to extreme heat. • Innovative thermoelectric cooling combats production derates and drought exposure.	Consider substation upgrades and more cost-effective Tx hardening methods • Significant exposure to days >105°F requires substation upgrades to avoid direct failure. • Widespread heat exposure necessitates upgrades that harden the entire length of a high voltage transmission line.	M	Gen: Microgrid funding through the Community Renewable Energy Grant Program addresses derating risk. T&D: No mention of substation upgrades, which face considerable extreme heat exposure and a high likelihood of failure.
 COLD	M		Focus weatherization technologies on thermoelectric & hydroelectric assets in NE • Many generators face continued exposure to icing and other cold-related failures through mid-century.	Prioritize investments in western population centers • Peak cold exposure coincides with population centers in the northwestern counties of the state, posing a threat of Dx and Tx icing and asset failure.	M	Gen: No proposed awards address generator cold exposure. T&D: Awarded projects for pole replacement and undergrounding address cold exposure.

ODOE could prioritize substation upgrades in the face of flood exposure, and fund data collection and analysis to better understand future drought and precipitation impacts

Key Takeaways

- ODOE could prioritize substation fortification for low-lying assets in western counties that are heavily exposed to flooding.
- Significant increase in drought exposure by mid-century suggests the importance of using climate-adjusted inputs for hydro generation forecasting.
- While precipitation has a weak climate signal, ODOE could seek out information about upstream precipitation and snow patterns to better assess risk.


Hazard	Exposure	Change to Mid-Century	 Generation	 Transmission & Distribution	AWPI*	Description
 FLOOD			Most supply technologies are not significantly exposed to flood • A handful of hydro generators in western counties are moderately exposed, which can cause dam overtopping and operational issues.	ODOE could prioritize substation fortification • High density of HV substations are heavily exposed to flooding, which can cause direct failure. • ODOE could also consider upgrades to aging or weak distribution poles.		Gen: Lack of exposure makes gen a lower priority for investment. T&D: No projects targeting substations, unaligned with the significant substation exposure.
 WIND		N/A	ODOE could consider investments to buttress solar racking and anticipate turbine cutouts • Supply-side planning for wind farms could include probability of cutout to anticipate supply shortages during wind events.	Critical HV ties in south-central OR could be prioritized for structure reinforcement • Consider rethinking regional design standards for poles given historical thresholds.		Gen: No wind/solar reinforcement despite significant exposure. T&D: Undergrounding & pole upgrades are aligned, but veg management projects could also be considered.
 DROUGHT			Grid operators could consider using climate-adjust inputs for hydro output forecasting • Drought exposure for the two largest hydro facilities increases 20-40% by 2050. • OR's heavy reliance on hydro generation means potential hydro output decreases could factor into resource planning.	Drought exposure does not have a material impact on transmission and distribution assets.		Gen: Microgrid funding is not sufficient to address risk of decreased hydro output. Suggested projects for heat and fire exposure could also address drought, including solar O&M advances.
 RAIN			ODOE could seek out additional data to understand future hydroelectric production • Coordinate with WSDOC to assess upstream precipitation effects on hydro output. • Consider the effect of warming on snow volume and melt timing.	Precipitation exposure does not have a material impact on transmission and distribution assets.		Gen: Weak climate signal makes addressing exposure less urgent, but ODOE could gather additional information to assess the true impact on hydro output and its implications for resource planning and scheduling.

Wildfire

Asset Analysis

ODOE could prioritize funding wildfire mitigation projects in Umatilla County and the wildland-urban interface bordering northwestern counties


Oregon Summer Fire Weather Index (FWI)
Distribution Assets (Population), Historical



KEY OBSERVATIONS

- Historical wildfire exposure is concentrated in Oregon's **eastern counties**.
- **D_x assets in Umatilla County exhibit high exposure** while western population centers with the most assets generally face lower exposure.
- High percentage of undergrounding and covered conductor proposals indicate general alignment with wildfire exposure; **ODOE could prioritize projects in eastern counties or counties bordering population centers.**

Oregon Summer Fire Weather Index (FWI)
Distribution Assets (Population), End-Century [RCP-8.5]




KEY OBSERVATIONS

- FWI increases by about 2-6 points across the state, demonstrating the importance of utilizing **forward-looking climate projections for state-wide fire mitigation planning.**
- Clackamas County**
- Large population center bordering high exposure counties, demonstrating the need for **fire mitigation projects in the wildland-urban interface.**

ODOE could consider prioritizing hardening for highly exposed remote transmission assets and explore novel operational procedures for renewables facing derating from soot and ash

Oregon Summer Fire Weather Index (FWI)
Generators & Transmission, Mid-Century [RCP-8.5]




Source: ClimRR, EIA860, HIFLD
15 | Copyright © Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information.

Key Highlights	Analysis
 Transmission	- Remote transmission assets are critical for last mile rural customers and are highly exposed in eastern counties. - Wildfire smoke can ionize the air around transmission lines, creating a conductor that can cause a line to arc directly to the ground. - HV lines in Wasco and Malheur counties could be prioritized for hardening upgrades.
 Renewables	- Wind and solar assets in Sherman, Gilliam, and Malheur counties face high levels of wildfire exposure. - Soot and ash from burns decrease capacity factors for both wind and solar assets. - Very few proposed projects address generator exposure, indicating a potentially overlooked resilience topic area for the state.
 Restoration	- Wildfire causes ingress/egress issues through destruction of roads and transportation, slowing restoration times for all assets. - ODOE could consider funding projects addressing wildfire-related access issues given its impact across all asset classes.

By mid-century, fire exposure is expected to increase in spatial extent, while by end-century it is expected to increase in severity and duration, shortening the maintenance window


Oregon Average Seasonal Fire Weather Index (FWI)
Population-Weighted by County [RCP-8.5]



KEY OBSERVATIONS

- **End-century wildfire exposure is elevated**, with the sharpest increase occurring between spring and autumn by about 14% from historical FWI.
- Elevated wildfire exposure around the summer suggests a **lengthening of the wildfire season** combined with an **increase in severity**.
- The change in length of wildfire seasons suggest that **the window for scheduled maintenance during the shoulder seasons is diminishing**.

Oregon Fire Weather Index Statistical Distribution (FWI)
Population-Weighted by County [RCP-8.5]



KEY OBSERVATIONS


- Increase in peak 1 (P1) by mid-century indicates that an **increasing percentage of the population** will be exposed to a **FWI level of about 10**.
- The tri-modal shape of the curve represents **three regions of the state that face distinct levels of fire risk** given differences in climate zones.
- A kink in the distribution between FWI 10-15 by end-century demonstrates **an increasing volume of the population being exposed to these increasingly severe FWI levels**.

Flood


Asset Analysis

ODOE could consider funding projects to fortify substations and distribution poles in western counties given the high volume of assets exposed to increasingly severe flooding

Oregon Average Annual Surface Runoff (mm/year)
Historical [SSP5-8.5]



Oregon Average Annual Surface Runoff (mm/year)
End-Century [SSP5-8.5]



KEY OBSERVATIONS

- Most flood exposure lies in the **northwest counties** given their relatively low elevations and proximity to the coast.
- **Multnomah and Clackamas counties have a large volume of Dx substations with high exposure** given their high population.
- Currently no proposed projects explicitly address flood exposure.

KEY OBSERVATIONS


- ODOE could consider funding projects to fortify low-lying Dx substations given the increase in flood exposure over time in western counties.

**Multnomah County**

Flood exposure is projected to increase ~23% by end-century, posing a substantial threat to a high density of substations and distribution poles.

ODOE could prioritize the fortification of high voltage substations given the high density of assets facing significant exposure and their high cost of failure

Oregon Average Annual Surface Runoff (mm/year)
Generators, Mid-Century [SSP5-8.5]




Key Highlights	Analysis
 Substation	- High voltage substations will be exposed to fluvial flooding if located in a flood plain or riverbank without necessary protections. - High density of HV substations in western counties are heavily exposed to flood risk, marking a priority for future hardening projects.
 Restoration	- Flooding causes ingress/egress complications by washing out access roads, contributing to restoration issues. - Flooding can affect on-site buildings or facilities, making it more difficult to maintain adequate staffing for oversight and restoration.
 Generators	- Most generator sites are not exposed to significant flood risk, indicating that ODOE could prioritize Tx & Dx projects to address the hazard. - A handful of hydro plants in Linn, Clackamas, and Multnomah counties are significantly exposed to flood, which can contribute to dam overtopping/failure and pose a threat to control houses.

Wind

Asset Analysis

Vegetation management and pole reinforcing could be prioritized for metro centers in southeastern counties as well as for remote customers in the south-central region


Oregon 100-year Wind Speed (mph)
Historical



Key Highlights	Analysis
 Distribution	- Given weak climate signals, wind speeds are derived using historical data and do not vary at high spatial resolution. - Rather than targeted investments, wind exposure should be addressed through upgraded design standards across a utility service territory.
 Lane County	- Lane County has a population of approximately 400k and 100-year return value of 95 mph, indicating a high exposure area for Dx assets. - Coincident extreme cold events put Dx lines at risk for galloping and asset failure due to ice loading on conductors.
 Lake County	Lake County has the highest return value of 126 mph, indicating high failure likelihood for lower class poles. - Although there might be less volume of Dx infrastructure, remote customers are at significant risk of prolonged outages.

HV transmission lines in south-central region of the state could be prioritized for mitigation investment given their critical import/export capacity with neighboring supply centers


Oregon 100-year Wind Speed (mph)
Historical



Source: DRI, EIA860, HIFLD
22 | Copyright © Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information.

Key Highlights	Analysis
 Transmission	- A series of MV-HV transmission lines in the south-central portion of the state are exposed to high historical wind speeds. - These are California-Oregon tie lines and are critical for import/export capability during extreme weather events. ODOE could focus on reinforcing Tx structures to mitigate risk.
 Solar	- A pocket of solar farms in the south-central portion on the state are historically exposed to ~126 mph at the 100-year return period. - Depending on OEM, solar panels are only rated to 90 mph, indicating need for rack reinforcement and vegetation management.
 Wind	- Wind farms cutout speeds can vary between 45-70 mph, indicating that in high wind speed events, there the turbines stop producing. - The cluster of wind farms located in the north-central area of the state are exposed to 100-year return period values of greater than the cutout threshold, impacting critical supply near population centers.

Historically, there is a 1% chance that the average wind speed seen across Oregon counties is ~80mph annually.




Key Highlights	Analysis
 High System Averages	- Historically, there is a 1% chance that the average wind speed seen across Oregon counties is ~80mph annually. - The 10% annual likelihood drops to 70mph, indicating high system wind speeds are common across counties.
 Volatility Across Counties	- There is a wide band between the maximum and minimum counties around the mean. - This indicates that wind adaptations should be focused on a county basis rather than over large service territories.

Heat

Asset Analysis

Significant increases in extreme heat exposure across the state suggest that ODOE could prioritize substation and Dx line upgrades to address derating, degradation, and risk of failure


Oregon Days Above 105 °F
Distribution Assets (Population), Historical



KEY OBSERVATIONS

- Currently T_x and D_x assets have **no exposure to days above 105 °F**.
- 105 °F is a particularly important threshold for distribution assets and substations, **which can fail when exposed to two consecutive days above 104 °F**.²

Oregon Days Above 105 °F
Distribution Assets (Population), End-Century [RCP-8.5]



KEY OBSERVATIONS

- Highly populated counties (Multnomah, Clackamas, Marion) are expected to face **about 8-10 days >105 °F annually, causing high asset utilization, derating, and potential failure.**

● **Umatilla and Morrow Counties**


20 days of extreme heat exposure necessitates substation and Dx line upgrades to mitigate potential failure and avoid derating.

¹Population bubbles are continuous and therefore labels are approximate. ²EPRI Climate READi

Source: ClimRR, US Census Bureau, City and Town Population Totals

ODOE could prioritize cooling technology development and cost-effective line adaptations to combat derating and line sag resulting from extreme heat exposure

Oregon Summer Average Maximum Temperature (°F)
Generators, Mid-Century [RCP-8.5]




Source: ClimRR, EIA860, HIFLD
26 | Copyright © Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information.

Key Highlights	Analysis
 Thermoelectric	- Thermoelectric generators that rely on water-based cooling methods will experience production derates as extreme heat raises average water temperatures. - ODOE could explore innovative cooling methods as a resilience topic area, as derates occur coincidentally with peak load.
 Renewables	- McNary Dam in Umatilla County is susceptible to extreme heat, which increases the likelihood of algal blooms that reduce output. - Solar assets in Malheur and Gilliam counties are significantly exposed to extreme heat, contributing to production derating at temperatures above 77°F.
 Transmission	- A significant portion of 220kV+ transmission lines are exposed to high levels of extreme heat, which can cause capacity derates and line sag. - Undergrounding proposals address these issues, but ODOE could consider more cost-effective adaptations to fortify longer portions of transmission lines.

Extreme heat days will become more common in Oregon, contributing to derating and capacity violations as well as substation failure, indicating the need for state-wide substation upgrades


Oregon Average Annual Cooling & Heating Degree Days (CDD & HDD)
Population-Weighted by County [RCP-8.5]



KEY OBSERVATIONS

- Between historical and mid-century, **the ratio of CDD to HDD increases**, with the share of average number of CDD jumping from about 9% to 15%.
- This results in **increased summer asset utilization and degradation**, but **impacts to winter utilization remain unclear** depending on heating electrification trends.
- Larger gap between HDD values than CDD values indicates that heating load will be more significantly impacted than cooling load.


Oregon Average Annual Days Exceeding Daily Max Heat Index Thresholds
Population-Weighted by County [RCP-8.5]



KEY OBSERVATIONS

- 2x increase in days with heat index >95 °F by mid-century demonstrates an **increase in peak load** and will likely contribute to **derating** and **capacity violations** for transmission and thermal generating units.
- 3x increase in days > 105 °F and 115 °F by poses a **substantial risk to distribution substations**, which can fail after two consecutive days above 104 °F without sufficient cooling infrastructure, indicating a potential focus area for ODOE in future funding allocation processes.

Average summer temperature maximums are projected to increase by mid-century, increasing the duration and magnitude of high system utilization




Key Highlights	Analysis
 Summer Warming	Heat risk increases most drastically in summer, with a 5 °F increase in the average seasonal max by mid-century, increasing system utilization and accelerating degradation.
 Shorter Shoulder Seasons	Warming is generally less pronounced in shoulder seasons, although increased autumn maximums could extend the duration of high system utilization and shorten maintenance windows.

Cold

Asset Analysis

ODOE could continue to fund distribution asset hardening and ensure that investment is aligned with Dx asset density given continued extreme cold exposure


Oregon Average Annual Minimum Temperature (°F)
Distribution Assets, (Population) Historical



KEY OBSERVATIONS

- Extreme cold coincides with large population centers in the western portion of the state, indicating **high levels of Dx asset exposure**.
- Prevalence of proposals including undergrounding and pole upgrades seems to address extreme cold exposure, but ODOE could **consider Dx asset density in its project awards going forwards**.

Oregon Average Annual Minimum Temperature (°F)
Distribution Assets, (Population), End-Century [RCP-8.5]



KEY OBSERVATIONS


- Climate projections cannot predict acute extreme events like polar vortices and winter storms, **underrepresenting cold exposure**.



Lane County is exposed to average annual minimum temperatures of about 36 °F, indicating potential **icing and freezing exposure for distribution assets**.

ODOE could consider resilience upgrades to gas plants and pipeline systems to combat cold exposure, as well as continued transmission hardening addressing freezing

Oregon Average Annual Minimum Temperature (°F)
Generators, Mid-Century [RCP-8.5]




Source: ClimRR, EIA860, HIFLD
31 | Copyright © Baringa Partners LLP 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information.

Key Highlights	Analysis
 Hydroelectric	Frazil ice formation and maloperation of spill gate motors can result in plant faults or production derates.
 Natural Gas	- Natural gas plants in the north-central region are exposed to average annual minimums of 37°F, which could cause ignition failure or performance issues if these plants lack heating equipment. No proposals addressing aging gas infrastructure, which requires hardening or replacement to mitigate cold exposure.
 Wind	Wind plants in Gilliam and Union counties face cold exposure that contributes to asset failure and ice throw.
 Freezing/Icing	- Despite warming, the prevalence of near-freezing annual minimums in many counties contributes to Tx freezing/icing risk that can cause asset failure. - ODOE appears to be addressing this issue through pole replacement and undergrounding.

Seasonal and annual temperature minimums are projected to increase over time across all seasons, indicating that ODOE could prioritize projects that address both heat and cold


Oregon Average Seasonal Minimum Temperature (°F)
Population-Weighted by County [RCP-8.5]



KEY OBSERVATIONS

- Significant winter warming (+5 °F by mid-century) will decrease overall heating load, but the **impact on electricity demand ultimately depends on the speed of heating electrification.**
- Mid-century winter minimums remain below 32 °F, indicating that **freezing and icing exposure persists despite warming.**
- Resilience upgrades like **undergrounding, covered conductors, or cable upgrades can address heat and cold exposure simultaneously.**

Oregon Average Annual Minimum Temperature (°F)
Population-Weighted by County [RCP-4.5, RCP-8.5]



KEY OBSERVATIONS


- ~8% increase in average annual minimum temperatures by mid-century indicates a reduction in heating load.
- Diverging temperature projections by end-century demonstrates projection uncertainty and the importance of continued monitoring.
- Regarding extreme cold, global climate models do not resolve for extreme cold events like polar vortexes, so **assets could still face similar levels of exposure to cold-related failures.**

Drought

Asset Analysis

Significant drought exposure increases necessitate climate-adjusted hydroelectric production forecasting and innovative cleaning and cooling solutions for solar and natural gas

Oregon Consecutive Days No Precipitation
Generators, Mid-Century [RCP5-8.5]



Key Highlights

Analysis



Hydroelectric

- A string of **hydroelectric plants along the Columbia River** bordering Sherman and Wasco Counties are exposed to peak state-wide drought levels.
- Asset owners and grid operators could be forecasting long-term production from these hydro facilities with **climate-adjusted inputs, as drought exposure in these counties increases by 20-40%.**



Natural Gas

- In arid conditions, **air intakes for CCGTs and CTs can clog and degrade** due to dust and sand particles, decreasing efficiency and longevity of the generator.
- Lack of water availability can **reduce natural gas cooling ability**, resulting in power production curtailments.




Renewables


- Drought conditions cause dust buildup on solar panels, hurting capacity factors.
- In areas that also have high wildfire exposure, **panel cleaning projects address two hazards simultaneously.**

Drought exposure will increase in spatial extent and severity by mid-century, but will become more evenly distributed by end-century

Oregon Average Annual Consecutive Days with No Precipitation
Population-Weighted by County [RCP 4.5, RCP-8.5]



Oregon Average Consecutive Days with No Precipitation Statistical Distribution
Population-Weighted by County [RCP-8.5]



KEY OBSERVATIONS

- **Drought exposure increases by ~17% by mid-century** (under RCP 8.5), contributing to potential asset cooling failures and reduced hydroelectric generation.
- Higher drought exposure for mid-century than end-century (RCP-8.5) demonstrates that **drought risk does not scale linearly with temperature** and could be monitored closely over time, especially by hydroelectric asset owners.

KEY OBSERVATIONS


- By mid-century, P1 and P2 increase and shift right, indicating **drought exposure will increase in spatial extent and severity**.
- Higher valley 1 (V1) level for end-century represents a significantly higher percentage of the population facing drought exposure of about 60 days and a **more even exposure distribution across the state**.
- Bimodal distribution for all time periods indicates **two distinct regions of drought exposure** within the state of about equal size.

Precipitation

Asset Analysis

Precipitation levels stay consistent to mid-century, but ODOE could consider the impacts of precipitation timing, upstream conditions, and changing snow patterns on hydro output

Oregon Annual Max Precipitation (in)
Generators, Mid-Century [RCP5-8.5]



Key Highlights	Analysis
 Timing	• Timing of precipitation has an important impact of hydro output. • Extreme rainfall events may overflow reservoirs and put more pressure on dams, increasing risk of failure. • Projections of increased drought and relatively constant annual precipitation indicate that extreme precipitation events may become more likely over time.
 Upstream Coordination	• Upstream precipitation and drought will have significant impacts on hydro production. • ODOE could establish a relationship with WSDOC to share information about precipitation conditions and hydro output.
 Changes to Snow Patterns	• While precipitation levels remain relatively constant to mid-century, precipitation type and timing is likely to change and could be monitored. • Grid operators could consider the impacts of less snow and earlier snow melt when conducting long-term planning.