

Disclaimer

This document: (a) is proprietary and confidential to Baringa Services Ltd (“Baringa”) and could not be disclosed to or relied upon by any third parties or re-used without Baringa’s consent; (b) shall not form part of any contract nor constitute acceptance or an offer capable of acceptance; (c) excludes all conditions and warranties whether express or implied by statute, law or otherwise; (d) places no responsibility or liability on Baringa or its group companies for any inaccuracy, incompleteness or error herein; and (e) is provided in a draft condition “as is” without warranty. Any reliance upon the content shall be at user’s own risk and responsibility. If any of these terms is invalid or unenforceable, the continuation in full force and effect of the remainder will not be prejudiced.

Copyright © Baringa Services Limited 2024. All rights reserved. This document is subject to contract and contains confidential and proprietary information. No part of this document may be reproduced without the prior written permission of Baringa Services Limited.

This report has been prepared by Baringa Services Ltd or a Baringa group company (“Baringa”) specifically for the client named in this report (“Client”) for the sole purpose of assisting the consideration of Client or interested investors (“Investors”) in the potential transaction named in this report (“Transaction”).

This report does not constitute a personal recommendation of Baringa or take into account the particular investment objectives, financial situations, or needs of Client or the Investors in relation to the Transaction. Client and Investors could consider whether the content of this report is suitable for their particular circumstances and, if appropriate, seek their own professional advice and carry out any further necessary investigations before deciding whether or not to proceed with the Transaction. This report could not, under any circumstances, be treated as a document containing complete and accurate information sufficient to make an investment decision. It is the responsibility of the Client and Investors to conduct such due diligence as necessary of any risk factors not identified in this report or which could affect the operation, financial standing and further development prospects of any assets being acquired, charged or sold in the Transaction. Baringa shall not be liable in any way for errors or omissions in information contained in this report based upon publicly available industry data or specific information provided by others (including Client, its affiliates, their advisers, target entity or any third parties). Baringa makes no representations or warranties (express or implied) concerning the accuracy or completeness of the information contained in this report, nor whether such information fully reflects the actual situation described in this report, and all conditions and warranties whether express or implied by statute, law or otherwise are excluded.

Information and data contained in this report is confidential and must not be disclosed to third parties by Client or Investors except as permitted in the relevant Client contract with Baringa or with the written consent of Baringa. This report may not be used in any processes involving the public offering in which shares of stock in a company are sold either privately or on a securities exchange. No part of this Report may be copied, photocopied or duplicated in any form by any means or redistributed (in whole or in part) except as permitted in the relevant Client contract with Baringa or with the written consent of Baringa. Copyright © Baringa Services Ltd 2024. All rights reserved.



State of the Grid Report

OREGON
DEPARTMENT
OF ENERGY



Energy & Resources | Networks

May 2025

Table of contents

1	Executive Summary
2	Scope & Background
3	Project Approach
4	Extreme Weather Outage Analysis
5	Utility Capital Plan Review
6	Appendix

Executive Summary

Historically, outages in Oregon have been driven by precipitation- and wind-related events. Small utilities can allocate more capital to harden against these hazards.



PROGRAM OBJECTIVE

Help state energy offices and select utilities assess how to use **40101(d) funding** to best strengthen the power grid against extreme weather, by:

- **Assessing** the unique **needs** of each state energy office
- **Analyzing future exposure to extreme weather** in the state, its coincidence with energy assets, and potential impacts
- **Attributing outages to weather events** and commenting on the alignment of utility capital spending with historical exposure
- Outlining a **benefit-cost methodology** to improve asset planning



DELIVERABLE OBJECTIVE

This deliverable seeks to:

- Attribute historical outages in the state to specific weather events and **comment on which events are driving the most customer interruptions in the state**
- Analyze a select utility's capital plan and **assess the alignment between their resilience spending and the weather events driving outages in their service territory**



KEY FINDINGS

Hazard Analysis:

Coincident **high winds** and **precipitation** should be a priority statewide

- Rainstorms and winter storms account for about 43% of all customer interruptions driven by extreme* outages
- High wind gusts are a primary hazard in all 3 of the most impactful weather events. Wind is attributable to more asset failure modes when compared to precipitation or extreme cold
- The top 3 events (rainstorms, winter storms, and windstorms) account for about 60% of all customer interruptions resulting from severe outages

Capital Planning Insights:

- High winds and precipitation underpin many of the extreme weather events that drive a high percentage of customer interruptions relative to their capital coverage.
- While COOP-3 is investing about 5-10% of it's capital plan in wind upgrades, there could be an opportunity to explore targeted vegetation management, pole trussing, and undergrounding

An extreme outage is defined as one in which >50% of customers in a county are out simultaneously, or at least 30,000 customers in a county experience an outage simultaneously, whichever is less

Sources: Found in slide notes

5 | Copyright © Baringa Partners LLP 2025. All rights reserved. This document is subject to contract and contains confidential and proprietary information.

Baringa Confidential

Despite the importance of wind and wildfire in the West, utilities could bolster their capital alignment with historical & future risk by conducting asset-level vulnerability assessments

STATE OF THE GRID REPORT | FINAL INVESTMENT CONSIDERATIONS



Invest against windstorms: Windstorms are the most widespread and severe cause of extreme outages across WECC in the past 5 years. While utilities are investing some capital against wind risk, the universal elevated exposure requires an increased volume of capital towards mitigations. Given its homogenous exposure, wind upgrades could be pursued as updates to design standards rather than targeted, ad hoc investments like substation upgrades.



Continue existing wildfire mitigations: While wildfire exposure of the past 5 years varies by geography, the cost of ignition remains inordinately high in comparison to other hazards. Therefore, even though ignition probability may be low, the high expected cost, coupled with the expected increase in exposure due to changes in climate, substantiates increased investment in mitigation. Utilities can better justify expensive investments like undergrounding by ensuring upgrades are done on feeders that are exposed to multiple hazards, having a double dividend effect on the investment.



Quantify extreme weather risk in dollars: In order to optimally allocate capital expenditures to buy down the most extreme weather risk for the least amount of dollars, utilities must quantify the cost and benefits of the risk and subsequent investment. The utilities that are most effectively optimizing their plans are implementing asset-level vulnerability assessments, using down downscaled climate projections to predict impacts out to mid-century. Baringa will be expanding on how to conduct such analysis in phase 4 of this project.

ASSET	INVESTMENT	COST	HAZARDS
POLES & STRUCTURES	Pole Reinforcement	M	3
	Pole Upgrades	M	3
	Dead-End Structures	M	2
	Decreased Span	M	2
	Pole Wrapping	L	1
CONDUCTORS	Undergrounding	H	4
	Reconductoring	M	4
	Covered Conductors	M	4
	Hardening/Rebuilds	L	1
SUBSTATIONS	Substation Elevation	H	1
	Control House Remediation	H	1
	Enclosures	H	3
	Reclosers/Switchgear	M	2
	Flood Walls	M	1
	Cooling Mechanisms	M	1
PLANNING TOOLS	Vegetation Management	H	3
	Dynamic Line Rating (DLR)	L	1
	Wildfire Planning Tools	M	1


The State of the Grid Report will provide recommendations and insights into most effective **resilience projects, highest risk locations**, and strategies for **improving capital spend efficiency**

1 STATE OF THE GRID REPORT | BENEFITS



Improved understanding of **how extreme weather impacts outage and ignition rates** in your service territory

DELIVERABLE | EXTREME WEATHER ANALYSIS



Analyze 5 years of publicly available extreme weather and outage data to **determine which type of events cause the largest outages and ignitions.**


Comment on expected change in outages and ignitions as a function of climate projections.

2 STATE OF THE GRID REPORT | BENEFITS



Actionable insights to **improve capital effectiveness** that addresses extreme weather risk

DELIVERABLE | INVESTMENT PLAN REVIEW



Review most recent investment plan to determine **effectiveness of normalized capital spend** in mitigating outages and ignitions from extreme weather.


Results will be anonymously compared with other participants to help outline resilience best practices and most effective mitigations.

Baringa is conscious of data privacy and sensitivities and is more than willing to work with your team to address concerns.

Extreme Weather Outage Analysis

Project Overview

Severe outages were mapped to corresponding weather events to better understand which forms of extreme weather are driving customer interruptions and how utilities can respond



Weather events were mapped to raw data to capture both single hazard and multi-hazard events. Events are considered extreme if the raw data is above the 90th percentile for the state

WEATHER EVENT		PRESENT WEATHER METRICS (Above 90 th percentile)
	EXTREME COLD	Min Temperature
	EXTREME HEAT	Max Temperature
	WILDFIRE	Fire Weather Index (FWI) OR Historical Ignition*
	EXTREME PRECIPITATION	Precipitation

WEATHER EVENT		PRESENT WEATHER METRICS (Above 90 th percentile)
	WIND STORM	Wind
	RAIN STORM	Wind + Precipitation
	SUMMER STORM	Wind + Precipitation + Max Temperature
	WINTER STORM	Wind + Precipitation + Min Temperature
	FLOODING	Surface Runoff

WEATHER EVENT
MAPPING
METHODOLOGY

Baringa analyzed 22 years of historical weather data for Colorado to determine 90th percentile weather hazard values across the state. During the mapping process, the algorithm considered whether the weather variables coincident with an outage were above or below the respective 90th percentile value and attributed the outage to a weather event based on the combinations show above. In the case of combinations not explicitly listed (i.e. extreme heat and high wind), the outage was mapped to the hazard deemed more likely to drive an outage (i.e. extreme heat and high wind → windstorm). A full list of mapping combinations can be provided upon request.

*Outages occurring within two days of a documented wildfire ignition in the county of origin were also attributed to wildfire, overriding other hazard combinations

Mapping outages to weather events more accurately captures the impact of coincident hazards, avoids double counting outages, and allows for flexible event definitions



Coincident Hazards

- **EXPLANATION:** Mapping to events captures unique threats posed to assets from coincident hazards
- **BENEFIT:** Multiple hazards occurring simultaneously can have different impacts on assets than considering each individually (e.g. coincident wind and snow/ice contributes to line galloping, wind and extreme heat could increase probability of vegetation contact given line sag due to heat).



No Double Counting

- **EXPLANATION:** Variable combinations are mapped to specific events
- **BENEFIT:** Ensuring that other hazards are below the 90th percentile isolates the most important hazards. Just looking at one hazards could capture outages that are actually attributable to other hazards.



Flexible Event Definitions

- **EXPLANATION:** Multiple different hazard combinations can be mapped to the same weather event given similar impacts to assets
- **BENEFIT:** Mapping to events allows for historical ignitions and extreme fire weather to be mapped to the same category, as both reflect ignition potential and can be addressed by similar upgrades.

Outages were classified as “severe” if more than 50% of customers OR more 30,000 customers in a given county are out at a single point in time

1 OUTAGE EVENT HANDLING



Define outage events to analyze coincidence with weather events and avoid double counting

METHODOLOGY

- 1 In a new column, assign “y” if “Customers Out” entry >0 in the data row, “n” if “Customers Out” = 0
- 2 Assign a unique event number to each string of consecutive “y” entries, separated by at least one “n” entry
- 3 For each unique event, keep the row with the maximum “Customers Out” value

DATASET | EAGLE-I



Comprehensive outage dataset from 2014-2022 created through a partnership between Oak Ridge National Lab and the U.S. DOE



Data is collected from utility’s public outage maps and provides 92% coverage of US and Territories

2 SEVERE OUTAGE CLASSIFICATION



Define “severe” outages in order to determine which weather events are coincident with the costliest outages in the state

DEFINITION

At least 50% of customers out in a given county

OR

At least 30,000 customers out in a given county

*whichever is less


SEVERE OUTAGES | JUSTIFICATION

Draws on ORNL’s “Analysis of Historical Power Outages in the United States and the National Risk Index,” in which the researchers determined the 30,000 customer metric as a conservative threshold to isolate extreme, weather-cause events

While ORNL uses a 15% customer outage threshold, we have increased it to 50% for this analysis to focus our insights on how to address the costliest and most severe outages in the state

The EAGLE-I dataset provides coverage for 90% of OR customers, but is missing data from a handful of rural counties in the north-central portion of the state

EAGLE-I CUSTOMER COVERAGE (%) (OR, 2018-2022)



INSIGHTS

Oregon generally enjoys better outage data fidelity in the EAGLE-I dataset than other states in WECC

- Counties across the state generally have high levels of outage coverage aside for a handful of sparsely-populated counties along the WA border served by smaller cooperatives or public power entities

A high volume of customers in the state are covered by the EAGLE-I dataset, indicating that it is still valuable for volumetric analysis

- Over 90% of customers in the state are covered in the EAGLE-I dataset
- Insights surrounding the volume of customer interruptions in the state will largely be aligned with real world exposure

Additional consideration could be given to the hazards faced by counties without outage data

- The weather events driving outages in counties with minimal data coverage will be underrepresented in this analysis
- While this may not have a large impact on the distribution of the volume of customer interruptions, it could significantly change the distribution of the count of outages associate with different hazards
 - North-Central Counties: Wildfire, Extreme Heat

WECC Summary

Windstorms are often the primary driver of customer interruptions in WECC, especially among smaller counties, but heat, wildfire, and rainstorms drive many interruptions along the coast

INSIGHTS

Windstorms are the most common primary driver of customer interruptions across WECC

- This is especially true among states in the eastern portion of the region such as Montana, Wyoming, and Colorado
- Wind is frequently the primary driver for counties with relatively fewer customer interruptions, indicating that it has an outsize impact on rural communities with radial networks and more overhead line mileage


A higher volume of total customer interruptions is generally concentrated along the coast

- More populous counties in CA, WA, and OR drive a higher volume of customer interruptions
- Coastal states demonstrate a wider range of primary driving hazards, including wildfire, extreme heat, flooding, and rainstorms

Extreme heat and wildfire are primary drivers of customer interruptions even in northern counties of the state

- While the northern portions of the state generally face less heat and wildfire exposure, these hazards are still driving customer interruptions because grid infrastructure could be less prepared for these events
- Per Baringa's Grid Resilience Reports, heat and wildfire exposure is projected to increase across the region out to mid- and end-century, potentially justifying hardening in historically less-exposed regions where this change will be most dramatic

PRIMARY DRIVER OF CUSTOMER INTERRUPTIONS BY COUNTY
(WECC, 2018-2022)



State Summary

Oregon



Typically, storms with high wind speeds and high precipitation drive the most frequent and impactful outages on the Oregon grid

HAZARD INSIGHTS

Storms typically drive severe outages on the Oregon grid

- Rainstorms and winter storms account for about 43% of all customer interruptions driven by extreme outages


Asset planners could prioritize addressing high winds to mitigate severe outages

- High wind gusts are a primary hazard in all 3 of the most impactful weather events. Wind is attributable to more asset failure modes when compared to precipitation or extreme cold

Wildfire’s accurate cost of ignition may be underrepresented in this analysis

- Given the destructive nature of wildfire, just looking at outages is insufficient to accurately represent the societal cost of wildfire. Additionally, ignitions that started in another state would not be captured in this analysis, despite posing a significant threat to assets in eastern Oregon

MOST IMPACTFUL HAZARDS	FUTURE OUTLOOK**	EVENT COUNT	MED. OUTAGE RATIO	TOTAL CUST. INTS.	AVG. CUST. INTS. / EVENT
 Rainstorm	➡	12	.56	328,431	27,239
 Winter Storm	➡	12	.56	299,441	24,953
 Windstorm	FURTHER RESEARCH NEEDED	10	.68	232,646	23,265



*A severe outage is defined as one in which >50% of customers in a county are out simultaneously, or at least 30,000 customers in a county experience an outage simultaneously, whichever is less
**Future outlook for the hazard severity based on Baringa’s Grid Resilience Report, completed as part of phase 2 of this analysis (Insert link to the GRR here)

Source: EAGLE-I, WRCC



The majority of customer interruptions from severe outages are concentrated among a few key weather events, mostly driven by high winds and precipitation

OUTAGE INSIGHTS

A handful of hazards drive the majority of severe customer interruptions across the state


- The top 3 events (rainstorms, winter storms, and windstorms) account for about 60% of all customer interruptions resulting from severe outages
- Including extreme precipitation this share of interruptions increases to 75%

Statewide resilience initiatives could specifically target wind and precipitation

- Targeting these hazards would address the weather events driving the vast majority of customer interruptions from severe outages
- The high cost of utility-caused ignitions makes this a more complicated tradeoff, as every dollar spent by a utility is not necessarily equal in risk reduction

Utilities could consider which events impact their climate zone

- Variable climate across the state indicates that local analysis is needed to determine the highest priority events
- Utilities could conduct asset-level vulnerability studies to inform asset planning, quantifying risk in dollars to compare across hazards and asset types




*A severe outage is defined as one in which >50% of customers in a county are out simultaneously, or at least 30,000 customers in a county experience an outage simultaneously, whichever is less



Rainstorms and flooding drive a high volume of outages in NW counties, but the wide range of primary outage drivers in Oregon reinforces the case for local, asset-level analysis

PRIMARY DRIVER OF CUSTOMER INTERRUPTIONS BY COUNTY (OR, 2018-2022)



INSIGHTS

The highest volume of customer interruptions is concentrated in highly populated NW counties

- The majority of customer interruptions in the region are attributable to rainstorms and flooding, prompting consideration of substation elevation

Primary drivers of customer interruptions vary widely across different regions of the state

- Oregon generally displays a more varied primary driver mix and fewer clear trends than other states in WECC, making asset-level analysis particularly important to ensure the most cost-effective investments are undertaken

Comparing customer interruptions to population reflects the reliability of different portions of the state's grid


- Josephine County experiences a relatively high volume of customer interruptions given its low population, indicating a potential area for additional investment
- Lane County experienced fewer customer interruptions than would be expected given its population
- Lane's high exposure to wind and extreme cold suggests that the grid infrastructure in this portion of the state is relatively resilient to extreme weather

PRIMARY DRIVER METHODOLOGY

- Map weather variable combinations to event definitions (see slide 15)
- Count the number of total customer interruptions at the county level (> 0 customers out) coincident with 90th percentile or greater weather variables for each of the combinations associated with a weather event
- Deem the event with the most coincident interruptions as the "primary driver"

Counties along the northern border of the state tend to experience the highest volume of interruptions per customer due to elevated climate exposure and vegetation density

**TOTAL CUSTOMER INTERRUPTIONS PER COVERED CUSTOMER BY COUNTY
(OR, 2018-2022)**



INSIGHTS

Rural counties along the Washington border tend to experience the highest volume of interruptions per customer in the state

- Counties with more customer interruptions per customer tend to be among the least populated in the state, as they likely have a large volume of overhead, radial distribution infrastructure that is particularly vulnerable
- However, this correlation between population density and reliability is weaker than other states in WECC, indicating that climate exposure and asset resilience could be more important drivers

More severe climate exposure could be driving outages in northern counties

- The group of less reliable counties along the northern border of the state experiences more extreme temperatures and precipitation events than the rest of the state
- These counties are also some of the most densely forested in the state, especially Clatsop and Wallowa, further contributing to outages

Many northern counties have low reliability


- The counties are served by a mix of providers, warranting further investigation into which utility is contributing more significantly to reliability issues
- This generally contrasts other states in WECC, in which small cooperatives and public power entities displayed markedly worse reliability than IOUs

METHODOLOGY

- Calculate the total number of customer interruptions that occur in a particular county, ensuring outage events are not double counted
- Divide this number by EAGLE-I's "covered customers" metric for the county

Utility-caused outages are concentrated in the northern and eastern portions of the state, aligning with the wildfire exposure identified in the Grid Resilience Report

UTILITY-CAUSED, TOP 10% IGNITIONS BY ACRES BURNED (OR, 2018-2022)



INSIGHTS

- Utility-caused ignitions are generally concentrated in the northern portion of the state**
- This generally corroborates Baringa’s findings in the OR GRR, which highlighted elevated wildfire exposure in northern and eastern counties in the state
 - Large, utility-caused ignitions in Clackamas County led to significant outages, with over 47,000 customers in the county losing power during the blaze
- Wildfire mitigation efforts could be expanded in Wasco and Clackamas Counties**
- Multiple utility-caused ignitions in each county across the lookback period indicates that this could be a potentially vulnerable region of the grid
 - At least three of these ignitions fall within the service territories of large IOUs (Portland General Electric and Pacific Power)
 - These ignitions occurred before 2020, prior to when IOUs were required to submit Wildfire Mitigation Plans to the PUC; regulators could investigate whether appropriate investment has been made in this region to reduce ignition risk

IGNITIONS METHODOLOGY

- Historical ignition data was collected from the FPA-FOD and the WFIGS Interagency Fire Perimeter Database
- We filtered out the **top 10% of ignitions by fire size across states in WECC**
- The map at left depicts these top 10% ignitions that also listed **“Power generation/transmission/distribution” as their NWCG cause code**
- The red boxes denote top 10% utility-caused ignitions that were also coincident with a severe outage in the ignition county within 2 days of the discovery date

1 Highest in WECC



Extreme outages are concentrated above the 99th percentile weather hazards, particularly precipitation, necessitating additional investment to avoid the costliest outage events

UNDERSTANDING THE DATA

Extreme outages (>50% of customers out) are more likely to be coincident with more severe winter storms


- About 80% of extreme outages are coincident with rainstorms in the 99th percentile or greater, compared to about 45% of non-extreme outages
- The gap between the curves at the 99th percentile shrinks to 20% when precipitation is excluded from the percentile mapping, indicating that it is a key determinant of outage severity, possibly due to correlation with storm severity/lightning

ASSET PLANNING INSIGHTS

Utilities could consider pole reinforcement or undergrounding to address wind exposure during rain storms

- Low-Cost:** Pole Reinforcement (Trussing, Guy Cables, Concrete Base, etc.), Pole Material Upgrades, Decreased Spans, Vegetation Management
- High-Cost:** Undergrounding

HAZARD	PRECIP	GUST SPEED
99TH PERCENTILE	0.12 (in.)	41 (mph)



Heavy snowfall contributes to the concentration of severe outages above 99th percentile winter storms, necessitating additional investment to avoid the costliest outage events

UNDERSTANDING THE DATA

Extreme outages (>50% of customers out) are more likely to be coincident with more severe winter storms


- About 65% of extreme outages are coincident with winter storms in the 99th percentile or greater, compared to about 37% of non-extreme outages
- The gap at the 99th percentile shrinks to 10% when precipitation is excluded from the percentile mapping, indicating that heavy snowfall is a key driver of severe outages (more than wind and cold)

ASSET PLANNING INSIGHTS

Utilities could consider pole reinforcement or undergrounding to address snow and ice loading, line galloping, and high wind speeds associated with winter storms

- **Low-Cost:** Pole Reinforcement (Trussing, Guy Cables, Concrete Base, etc.), Pole Material Upgrades, Decreased Spans, Vegetation Management, Covered Conductors
- **High-Cost:** Undergrounding

HAZARD	PRECIP	GUST SPEED	MIN TEMP
99TH PERCENTILE	0.12 (in.)	41 (mph)	20°F



Extreme outages are generally attributable to higher wind speeds, but a high coincidence of outages with low wind speeds indicates vegetation contact could be a key driver

UNDERSTANDING THE DATA


Extreme outages (>50% of customers out) are more likely to be coincident with >43 mph wind speeds than non-extreme outages

- About 30% of extreme outages are attributable to wind speeds above 43 mph, compared to under 20% of non-extreme outages
- Outage severity is generally less sensitive to wind speed than other states in WECC
 - Wind is likely driving less direct asset failure due to high vegetation density and relatively lower wind speeds

ASSET PLANNING INSIGHTS

Prioritizing vegetation management and active inspection could address a significant portion of wind-driven outages

- Over 97% of extreme and non-extreme outages occur at wind speeds < 50 mph, which are more likely attributable to vegetation contact or aging equipment rather than direct failure
- Outages are coincident with wind speeds up to 83 mph, which could serve as an important threshold for planning and design
- **Low-Cost:** Pole Reinforcement (Trussing, Guy Cables, Concrete Base, etc.), Pole Material Upgrades, Decreased Spans, Vegetation Management
- **High-Cost:** Undergrounding



Utility Capital Plan Review

Project Overview

Background & Approach

We have a total of 12 utilities across WECC participating in this analysis, 5 public power, 5 cooperatives, 2 investor-owned utilities

STATE	UQID
California	PUBLIC-1
Arizona	PUBLIC-2
Washington	PUBLIC-3
Nevada	PUBLIC-4
Washington	PUBLIC-5

STATE	UQID
Colorado	COOP-1
New Mexico	COOP-2
Oregon	COOP-3
Utah	COOP-4
Wyoming	COOP-5

STATE	UQID
Montana	IOU-1
New Mexico	IOU-2

Severe outages were mapped to corresponding weather events to better understand which forms of extreme weather are driving customer interruptions and how utilities can respond



ANALYZE 2024 UTILITY CAPITAL PLANS

Purpose: Review projects listed in capital plans and categorize into standardized buckets of utility spending



MAP RESILIENCE INVESTMENTS TO HAZARDS

Purpose: Determine which types of investments mitigate or adapt the utility network to certain extreme weather events



ASSESS INVESTMENTS-EXPOSURE ALIGNMENT

Purpose: Normalize spend across relevant utility metrics and determine the degree to which capital allocation aligns with historical extreme weather exposure

CAPITAL PLAN	
Project	\$(k)
Undergrounding	900
Reconductoring	75
Substation Upgrade	500

TECHNOLOGY, PREDICTION, IMAGING

ASSESSMENT & REPAIR

SYSTEM UPGRADES

... additional spend categories in slide 34

Individual projects in utility capital plans are mapped to standardized buckets in order to compare spend between utilities

TECHNOLOGY, PREDICTION, IMAGING

ASSESSMENT & REPAIR

SYSTEM UPGRADES

... additional spend categories in slide 34

WILDFIRE


EXTREME HEAT

MAPPED TO 9 SEPARATE EVENTS

Project categories are ascribed a value as to generally how effective they are at addressing each extreme weather variable.

UTILITY INVESTMENT-OUTAGE ALIGNMENT | COOP-3

While COOP-3 has high coverage of extreme heat events, there is an opportunity to explore targeted resilience investments that address asset failures due to wind and precipitation.



INVESTMENT-OUTAGE DIVERGENCE: L M H

The level of capital spend addressing each weather event is compared to the share of customer interruptions it drives




Individual projects and line items within the capital plans were mapped to larger buckets to allow for standardized comparison across utilities

CATEGORY	DEFINITION	SUBCATEGORIES
 TECHNOLOGY, PREDICTION, IMAGING	Investments in analysis and tools that improve asset management, asset planning, and operational efficiencies.	Modeling, Remote Sensing, Mapping
 ASSESSMENT & REPAIR	Investments needed to repair or replace damaged or end-of-life distribution equipment like-for-like.	Like-for-like equipment replacement
 SPECIAL PROGRAMS	Investments needed for non-traditional capital and other unique projects.	Demand Response/VPP, Wildfire Training Environmental/Ecological Protection
 SYSTEM UPGRADES	Investments in existing assets that improve the capacity, reliability, resilience, etc. of the system.	Transformer Capacity Upgrades, Pole Replacement/Reinforcement, Reconductoring Undergrounding, Voltage/Phase Upgrades
 NEW CONSTRUCTION	Investments in brand new assets and equipment.	New Lines, New Substations, New Customer Interconnection
 ADMINISTRATIVE	Investments in supporting infrastructure and processes for capital planning and operations.	Fleet, Building Remodeling, Travel, Education, Salaries
 WILDFIRE MITIGATION	Investments in system upgrades, adaptations, mitigations, that lower the likelihood of wildfire ignition and prevent damage to assets.	Investments that explicitly address wildfire risk.

Capital Plan Review

Cooperatives’ and public power entities’ highest categories include system upgrades and new construction, while IOUs generally spend more on wildfire mitigation



ALL UTILITIES

- System upgrades make up a significant portion of capital spending across all utility types, indicating that resilience is a key focus area
- Many utilities are also spending substantially on new construction, increasing capacity to serve new customers and large loads
 - This corroborates recent data showing new transmission and distribution expenditures driving the bulk of utility spending increases in recent rate cases

COOPS

- Cooperatives typically prioritize system upgrades in their capital allocation, demonstrating a prevalence of aging equipment and focus on resilience

PUBLIC POWER


- Public power entities spend significant sums on both system upgrades and new construction and often have extensive undergrounding programs

IOUs

- Generally spend more on wildfire mitigation given the commonplace requirement to file Wildfire Mitigation Plans (WMPs) with the PUCs

1 IOU-1 provided their Wildfire Mitigation Plan rather than their exhaustive capital plan, resulting in a high percentage of wildfire mitigation spending

Cooperatives spend less per line mile, while public power entities are generally more reliable; IOUs fall somewhere in between these two utility types on the spend vs. reliability matrix



INSIGHTS

COOPS

- Cooperatives typically spend less per line mile, indicating lower overall spend given their medium-sized service territories
- Wide range of reliability could be driven by different levels of spend effectiveness or extreme weather exposure

PUBLIC POWER

- Public power entities have higher reliability given their smaller territories and higher percentage of underground equipment
- Less area and more expensive upgrades indicate high spend per line mile, though entities that are outliers could be spending less effectively

IOUs

- IOUs see both high reliability and relatively low spend per mile
- Being subject to strict oversight from a state regulator could improve IOUs' reliability and spend effectiveness
- Given their larger service territories and customer counts, IOUs could benefit from economies of scale that increase spend effectiveness (i.e. admin, procurement, etc.)

¹ An estimate of IOU-1's total capital spend was considered in this view, not just Wildfire Mitigation Plan spending

Utility Investment-Outage Alignment

Weather Event	Share of Capital Investment (%)	Share of Total Customer Interruptions (%)
Extreme Heat	10.5	3.0
Wildfire	10.8	12.0
Wind Storm	7.0	15.2
Summer Storm	11.0	2.5
Winter Storm	7.0	20.5
Rain Storm	7.0	23.5
Extreme Cold	7.0	16.0
Flood	4.0	0.0



Assessment: Investments that address general capacity needs also mitigate heat risk. Therefore, coverage could be attributed to transformer upgrades or reconductoring, positioning COOP-3 well for future temperature increases.

WIND
STORM

H



WINTER
STORM

H

While COOP-3 is investing about 5-10% of it's capital plan in wind upgrades, there could be an opportunity to explore targeted vegetation management, pole trussing, and undergrounding.

**UNCERTAIN
COVERAGE**

Assessment: COOP-3's capital expenditures exhibit roughly average alignment with climate exposure compared to other utilities in WECC. The utility could consider conducting an asset-level risk assessment using future weather data to clarify future exposure.



34 | Copyright © Baringa Partners LLP 2025. All rights reserved. This document is subject to contract and contains confidential and proprietary information.

Utility Benchmark Analysis


Utilities with convergent coverage are investing in upgrades that address hazards that have been historically responsible for the most severe outages in their service territory

RANKING OVERALL UTILITY COVERAGE OF EXTREME WEATHER EXPOSURE GIVEN CAPITAL INVESTMENTS

Utility Comparison Chart

Utilities that are **DIVERGENT** see a lower proportion of their capital plan cover the hazards that historically drive outages

Utilities that are **CONVERGENT** see a higher proportion of their capital plan cover the hazards that historically drive outages



Utilities in WECC generally underinvest in windstorms given their widespread severity over utility service territories. Wildfire remains a highlight hazard for continued investment.

RANKING OVERALL UTILITY COVERAGE OF EXTREME WEATHER EXPOSURE GIVEN CAPITAL INVESTMENTS

Hazard Comparison Chart

